

東芝照明器具配光データシート

| | |
|----|-------------------|
| 名称 | LED防爆器具 |
| 形名 | LEDQ-72861SES-LS9 |

| | |
|--|--|
| | |
|--|--|

| | | |
|--------|------|---------|
| 効 率 | F | 0 % |
| | F | 100 % |
| | F | 100 % |
| | 器具光束 | 7200 lm |

| | | |
|---------|---|------|
| 保守 率 | 良 | 0.86 |
| | 中 | 0.83 |
| | 否 | 0.79 |

| | | |
|--------|-----|---|
| 最大取付間隔 | | |
| A-A | 1.3 | H |
| B-B | 1.3 | H |

| | |
|----|--|
| 備考 | |
|----|--|

| | |
|-----|--|
| 前面 | |
| 反射面 | |

| 光度 (cd/1000lm) | | | |
|-------------------------|-----|-----|-----|
| $\theta \setminus \phi$ | A-A | B-B | C-C |
| 0° | 377 | | |
| 10° | 372 | | |
| 20° | 354 | | |
| 30° | 323 | | |
| 40° | 278 | | |
| 50° | 217 | | |
| 60° | 143 | | |
| 70° | 72 | | |
| 80° | 21 | | |
| 90° | 0 | | |
| 100° | 0 | | |
| 110° | 0 | | |
| 120° | 0 | | |
| 130° | 0 | | |
| 140° | 0 | | |
| 150° | 0 | | |
| 160° | 0 | | |
| 170° | 0 | | |
| 180° | 0 | | |

| 反射率 (%) | 天井 | 80 | | | | | | 70 | | | | | | 50 | | | | | | 30 | | | | | | 20 | | | | | | 0 | | | | | |
|---------|---------------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|----|---|--|--|--|
| | 壁 | 70 | | 50 | | 30 | | 70 | | 50 | | 30 | | 50 | | 30 | | 30 | | 30 | | 10 | | 0 | | 30 | | 10 | | 0 | | 10 | | 0 | | | |
| | 床 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | 30 | 10 | | | | |
| 室指数 | 固有照明率 (×0.01) | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 0.60 | 65 | 59 | 51 | 48 | 42 | 41 | 63 | 58 | 50 | 48 | 42 | 41 | 48 | 47 | 41 | 40 | 41 | 40 | 36 | 34 | | | | | | | | | | | | | | | | | |
| 0.80 | 77 | 70 | 64 | 60 | 55 | 52 | 75 | 69 | 62 | 59 | 54 | 52 | 60 | 58 | 53 | 51 | 52 | 51 | 47 | 45 | | | | | | | | | | | | | | | | | |
| 1.00 | 84 | 76 | 71 | 66 | 62 | 59 | 82 | 74 | 70 | 65 | 61 | 59 | 67 | 64 | 60 | 58 | 59 | 57 | 53 | 51 | | | | | | | | | | | | | | | | | |
| 1.25 | 92 | 82 | 80 | 73 | 71 | 66 | 89 | 80 | 78 | 72 | 70 | 66 | 75 | 70 | 68 | 65 | 66 | 64 | 60 | 58 | | | | | | | | | | | | | | | | | |
| 1.50 | 97 | 86 | 85 | 78 | 77 | 71 | 94 | 84 | 84 | 77 | 76 | 71 | 80 | 75 | 73 | 70 | 71 | 69 | 65 | 63 | | | | | | | | | | | | | | | | | |
| 2.00 | 105 | 92 | 95 | 85 | 87 | 80 | 102 | 90 | 93 | 84 | 86 | 79 | 88 | 82 | 82 | 78 | 79 | 77 | 73 | 71 | | | | | | | | | | | | | | | | | |
| 2.50 | 110 | 95 | 101 | 89 | 94 | 84 | 106 | 93 | 98 | 88 | 92 | 84 | 93 | 86 | 88 | 82 | 84 | 81 | 78 | 76 | | | | | | | | | | | | | | | | | |
| 3.00 | 113 | 97 | 105 | 92 | 99 | 88 | 109 | 96 | 102 | 91 | 96 | 87 | 97 | 89 | 92 | 86 | 88 | 84 | 81 | 79 | | | | | | | | | | | | | | | | | |
| 4.00 | 118 | 100 | 111 | 96 | 106 | 93 | 113 | 99 | 108 | 95 | 103 | 92 | 102 | 93 | 98 | 90 | 93 | 89 | 86 | 84 | | | | | | | | | | | | | | | | | |
| 5.00 | 120 | 102 | 115 | 99 | 110 | 96 | 116 | 100 | 111 | 97 | 107 | 95 | 105 | 95 | 101 | 93 | 96 | 91 | 89 | 87 | | | | | | | | | | | | | | | | | |
| 10.00 | 126 | 105 | 123 | 103 | 120 | 102 | 121 | 104 | 118 | 102 | 116 | 101 | 111 | 100 | 99 | 103 | 97 | 95 | 93 | | | | | | | | | | | | | | | | | | |

